

## AMEV attestation for certified BACnet devices

### 1. The following BACnet device is certified as per DIN EN ISO 16484-5:

Supplier	MBS GmbH		
Product name	MBS Universal-Gateway		
Product model number	Single-X, Double-X, Triple-X		
Standard device profile	B-BC, B-GW, B-BBMD	BACnet protocol vers. / rev.	1.22
Firmware revision	1.22		

Data link layer options	<input checked="" type="checkbox"/> BACnet IP (Annex J)	<input type="checkbox"/> BACnet over LonTalk
	<input checked="" type="checkbox"/> BACnet MS/TP master	<input type="checkbox"/> BACnet MS/TP slave
	<input checked="" type="checkbox"/> MS/TP baud rates: 9600, 19200, 38400, 57600, 76800, 115200	
	<input type="checkbox"/>	
Static device binding	<input type="checkbox"/> Yes (for MS/TP only)	
Networking options	<input checked="" type="checkbox"/> BBMD	<input checked="" type="checkbox"/> Reg. by foreign device
	<input type="checkbox"/> Router, medium:	
Character set	<input checked="" type="checkbox"/> UTF-8	
Reporting options	<input checked="" type="checkbox"/> Intrinsic reporting	<input checked="" type="checkbox"/> Algorithmic reporting

### 2. The device supports BACnet functions as per AMEV profile:

<input type="checkbox"/> AMEV profile AS-A (Automation station, base version)	As of:
<input checked="" type="checkbox"/> AMEV profile AS-B (Automation station, extended version)	As of: AMEV BACnet 2017
<input type="checkbox"/> AMEV profile	As of:

### 3. Basis for AMEV attestation:

<input checked="" type="checkbox"/> Test report of test lab TÜV SÜD Industrie Service GmbH dated 04.11.2021 number BAC01008
<input checked="" type="checkbox"/> AMEV recommendation BACnet 2017 As of: 01.08.2017 (see <a href="http://www.amev-online.de">www.amev-online.de</a> )

### 4. The AMEV attestation is only valid in combination with the certificate:

<input checked="" type="checkbox"/> Certificate number BTL-30822 (see <a href="http://www.bacnetinternational.net/btl">http://www.bacnetinternational.net/btl</a> )
---

Köln, 01.03.2022



Dipl. Ing. (FH) Eike Hinck  
Gebäudewirtschaft der Stadt Köln  
Ottoplatz 1  
50678 Köln  
Germany  
Tel.: +49 221 – 221 23435  
Email: Eike.Hinck@stadt-koeln.de

(AMEV chairman BACnet)

# WSP CERT



Dr.-Ing. Frank Bitter  
Kapuzinerweg 7  
70374 Stuttgart  
Germany

(BACnet certification body)